



### DETAIL NOTES:

1. MATERIAL AND METHODS OF CONSTRUCTION SHALL BE IN CONFORMANCE WITH THE LATEST EDITION OF THE NEW YORK STATE DEPARTMENT OF TRANSPORTATION (NYS DOT) STANDARD SPECIFICATIONS FOR CONSTRUCTION AND MATERIALS.
2. ALL WORK SHALL CONFORM WITH SECTION 608 *SIDEWALK, DRIVEWAYS, AND BICYCLE PATHS* OF THE NYS DOT STANDARD SPECIFICATIONS, REFER TO NOTE NO. 1 ABOVE.
3. CONCRETE MATERIALS, PLACEMENT AND CONSTRUCTION SHALL CONFORM WITH SECTION 500 *PORTLAND CEMENT CONCRETE* OF THE NYS DOT STANDARD SPECIFICATIONS, REFER TO NOTE NO. 1 ABOVE.
4. REINFORCING STEEL FOR CONCRETE SHALL CONFORM WITH SECTION 556 *REINFORCING STEEL FOR CONCRETE STRUCTURES* OF THE NYS DOT STANDARD SPECIFICATIONS, REFER TO NOTE NO. 1 ABOVE, AND AS SPECIFICALLY CALLED OUT IN THE DRAWINGS.
5. SUBBASE MATERIAL SHALL CONFORM WITH SECTION 304 *SUBBASE COURSE* OF THE NYS DOT STANDARD SPECIFICATIONS, REFER TO NOTE NO. 1 ABOVE.
6. CONCRETE SIDEWALK IN THE EAST END HISTORIC DISTRICT SHALL BE DYED WITH BUTTERFIELD UNI-MIX® U28 CHARCOAL OR APPROVED EQUIVALENT AND STAMPED WITH EIGHTEEN (18) INCH BY THIRTY-SIX (36) INCH BLUESTONE BY BUTTERFIELD COLOR, PRODUCT NUMBER BST4210 OR APPROVED EQUIVALENT. A SET OF STAMPS ARE AVAILABLE FROM THE CITY OF NEWBURGH CODE COMPLIANCE OFFICE. THE FINISHED SIDEWALKS SHALL BE SEALED WITH BUTTERFIELD COLOR® CLEAR-GUARD™ CURE & SEAL CLEAR GUARD PRO 350 OR APPROVED EQUIVALENT WITH A POLYMER ADDITIVE DESIGNED TO ADD TO SEALER FOR A SLIP-RESISTANT SURFACE.
7. EXPANSION JOINTS SHALL BE INSTALLED AT ALL EXISTING IMMOVABLE OBJECTS, AT CONSTRUCTION COLD JOINTS, AND AS PER THE SPACING IDENTIFIED IN THIS DETAIL OR SPECIFICALLY CALLED OUT IN THE DRAWINGS.
8. NO JOINTS SHALL NOT BE SAW CUT. ALL JOINT SHALL BE AS PER THE STAMPED TEXTURE OR TOOLED, REFER TO NOTE NO. 6 ABOVE.
9. WHERE IT IS NECESSARY TO PLACE FILL FOR PURPOSE OF BRINGING THE SUBGRADE ELEVATION UP TO A SPECIFIED GRADE, THE FILL MATERIAL PLACED SHALL BE IN CONFORMANCE WITH SECTION 203 *EXCAVATION AND EMBANKMENT* OF THE NYS DOT STANDARD SPECIFICATIONS, REFER TO NOTE NO. 1 ABOVE.
10. THE FINISHED SIDEWALK SHALL BE SEALED WITH PROSDCO CONSOLIDECK SALTGUARD WB PENETRATING WATER AND SALT BARRIER, EUCLID CHEMICAL COMPANY BARACADE SILANE 100 SILANE WATER AND SALT REPELLENT, OR APPROVED EQUIVALENT.